

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CT0147**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	OMB SALERI S.p.A. Via Rose di Sotto, 38/c, I-25126 Brescia
Distributor <i>Vertreiber</i>	OMB SALERI S.p.A. Via Rose di Sotto, 38/c, I-25126 Brescia
Product Category <i>Produktart</i>	gas fittings: Valve combined with thermally triggered shut-off device (4341)
Product Description <i>Produktbezeichnung</i>	angle pattern or straight pattern ball valve with excess flow valve (GS) in the closed body and optionally with integrated thermally triggered shut-off device (TAE)
Model <i>Modell</i>	VAIT 356.01. ...; VAI 357.01. ...; ROAI 352.01. ...
Countries of Destination <i>Bestimmungsländer</i>	DE
Test Reports <i>Prüfberichte</i>	type testing: 18/024/4341/236 from 04.04.2018 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 331 (01.04.2016) DIN 3586 (01.10.2003) DIN 3387-1 (01.11.2008) DVGW VP 305-1 (01.12.2007)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	07.05.2028 / 18-0293-GEE

07.05.2018 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
fuel gases according to G260	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
VAIT 356.01. ...; VAI 357.01. ...; ROAI 352.01.700	nominal diameter: DN 15 ambient temperature range: -20...+60 °C max. operating pressure: 0,1 bar	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
...040/045/070/075/080/110/120; ROAI	straight pattern ball valve
...010/020/025/030/050/055/060/090/100	angle pattern ball valve
VAIT 356.01. ...	with TAE; accuracy temperature TAE: +95 °C (+/-5K); thermal resistance: +650 °C for operating pressure up to 1 bar, class C1
VAI 357.01. ...; ROAI 352.01.700	without TAE

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

connection: depending on variation at the input side and/or at the output side internal thread Rp 1/2 and/or external thread R 1/2, in each case according to DIN EN 10226-1; at the output side also internal- or external thread G 1/2 or on both sides also external thread according to DIN ISO 228-1 (with additional sealing element)
excess flow valve: GS 1.6 - type K (operating pressure range 15...100 mbar)
installation position: horizontal